

Ryan Field – Tucson, Arizona
Rehabilitate Runway 6L/24R – 20124620

AIP 3-04-0044-039-2025

ADDENDUM NO.2
April 25, 2025

The Solicitation is amended by the following clarifications/changes/additional information. If any provision in this Addendum conflicts with any existing provisions in the Solicitation, this Addendum will control. All other terms, conditions, and provisions of the Solicitation remain in effect as published. The bid opening date and time remain unchanged.

1. Questions:

- a. Would you happen to have any specs about the edge lights? Any details we could get on those would be helpful for planning any temporary removal and resetting at repair areas where it would be unavoidable.

Response: In locations where contractor chooses to temporarily remove light fixture in lieu of protecting in place. They shall remove light fixture and baseplate and store for reinstallation. Install shorting cap on transformer secondary and 3/8" thick blank steel cover plate on light base. After completion of pavement work, remove shorting cap and cover plate and reinstall existing light fixture and baseplate with new gasket under baseplate. Contractor shall follow lock out/tag out procedures

END OF ADDENDUM NO.2

Bidder is required to acknowledge this addendum in their bid form.

Prepared by:

Stantec Consulting Services Inc.
1 South Church Ave, Suite 2100
Tucson, AZ 85701

