

**NOTICE TO ALL BIDDERS**

**ADDENDUM NO. 2  
TO  
TUCSON AIRPORT AUTHORITY  
TUCSON INTERNATIONAL AIRPORT**

**10223504 DESIGN & CONSTRUCTION OF NEW HVAC FOR WAREHOUSE AND ARCHIVES**

**MAY 31, 2023**

In accordance with the Bid Documents, Bidders on the above-referenced project are hereby notified that the following Addendum, dated May 31, 2023, shall be made a part of the Bid Documents. The Bidder shall acknowledge receipt of this addendum on the Bid Form.

**GENERAL**

No changes at this time.

**PROJECT SPECIFICATIONS AND CONTRACT DOCUMENTS**

**PROJECT PLANS**

No changes at this time.

**RESPONSES TO QUESTIONS**

1. Does TAA have a rough schedule/timeline in mind for this project?  
Response - Page 2 of the front end documents indicates substantial completion a maximum 365 calendar days after NTP but ideally TAA wants to see the project installed and complete as soon as possible. Please also see page 61 of the front end documents (Article 9.1) also talks about timing and project schedule.
2. Section 5 on page 19 asks for financial information from the bidders. Is that required at the time of bid or when the contract is awarded?  
Response - The financial information is due at the time of the Bid. We ask for audited financial statements. If the Bidder comes back and says that they do not have a current audited statement, we will accept a recent balance sheet and income statement.
3. Please provide specification a/o detail for the rubber curtain over the roll-up doors, referenced on Sheet M2.0 of the drawings.

Response - Please provide equal of Akon products stand off strip curtain with factory stand-off mounting, standard smooth strips with 6-8" wide 0.120" thick strips and +/-50-66% overlap rated for medium/heavy foot and pallet truck traffic.

<https://www.curtain-and-divider.com/pvc-strip-curtains/stand-off-strip-curtain/>

4.

**MISCELLANEOUS**

No changes at this time.

End of Addendum #2